


Product information and test conditions

Name	T8 Flicker Free	
Time	2019-12-11 11:02:58(Time-zone GMT+8)	
Manufacturer	Waveform Lighting	
User	Waveform Lighting (hello@waveformlighting.com)	
Temperature(°C)	Humidity(%)	Distance(m)


Parameters

CIE_x	0.3134
CIE_y	0.3262
CIE_u'	0.1994
CIE_v'	0.4669
CCT	6491 K
CRI (Ra)(R1~R8)	98
CQS	96
TLCI(Qa)	99
GAI	99
TM-30-15 Rf	93
TM-30-15 Rg	100
Illuminance	6,149 lux
Foot Candle	571.2 fc
λ_p	450 nm
Flicker Percentage	2 %
Flicker Index	0.00
Flicker Frequency	121 Hz


Spectrum




CIE 1931




CIE 1976



C78.377 - 2017



IEC-SDCM



CRI (Re) (R1-R15)

R1	98	R6	96	R11	98
R2	99	R7	98	R12	80
R3	99	R8	98	R13	99
R4	99	R9	98	R14	100
R5	98	R10	98	R15	96